

Columbia Township Planning Commission
July 29, 2003

Called to order 7:30

Present Gaede, May, Holmstrom, Parker, Wahr, Watkins
Absent Kuzminski

Fellowship Baptist Church Site Plan:

Submitted revised plan to show storm water runoff. Letter of approval from County
Drain Commissioner,

This plan only is approved for gravel parking lot. The retention basin is only designed
for the roof of the 80x100 building.

Motion to recommend to the township board, approval of the site plan if and when they
pave the parking and or drives they must submit plan for the additional water runoff.
Motion by May, second by Holmstrom; Ayes all.

Minutes of July 15, 03. Motion to approve by Wahr, second by May, ayes all.

Workshop

Completed Section VII

Completed Section VIII

Adjourned at 9:28

Don Watkins, acting secretary